

ORDINANCE NO. 1037

AN ORDINANCE OF THE CITY OF KIRKLAND RELATING TO FIRE PROTECTION AND PREVENTION AND PRESCRIBING REGULATIONS GOVERNING CONDITIONS HAZARDOUS TO LIFE AND PROPERTY FROM FIRE, AND AMENDING SECTION 28.13 OF THE KIRKLAND FIRE PREVENTION CODE, ORDINANCE NO. 953, AS SUPPLEMENTED BY ORDINANCE NO. 1028.

BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF KIRKLAND AS FOLLOWS:

Section 1: Section 28.13 of the Kirkland Fire Prevention Code, being Ordinance No. 953, as heretofore supplemented by Ordinance No. 1028, is hereby amended to read as follows:

Section 28.13 No portion of any building or other structure supported by piers or piling and extending over water shall be more than 250 feet from an improved public street or alley giving access thereto for fire engines and other fire fighting apparatus and equipment, provided, however, that a building or structure which meets the following conditions may extend an additional 75 feet;

- (a) Said building or structure shall be designed in accordance with the requirements of Fire Zone 2; and
- (b) Said building or structure shall have a minimum of 45% total "frontal openness" as defined in Section 4.8.243 (D) of Ordinance No. 1015.

Section 2: Ordinance No. 953, the Fire Prevention Code for the City of Kirkland, as heretofore amended, is in all other respects hereby ratified and confirmed.

Section 3: This ordinance shall be in force and take effect five days from and after its passage by the Council and publication as required.

PASSED by the Kirkland City Council in regular meeting on the 20th day of June, 1966.

SIGNED in authentication thereof the 20th day of June, 1966.

James G. Vaux  
Mayor

Attest:  
Ellen W. Lucas  
Director of Administration & Finance  
(Ex Officio City Clerk)

Approved as to form:  
Ralph A. Turner  
City Attorney