

RESOLUTION NO. R- 2572

A RESOLUTION OF THE CITY COUNCIL OF THE CITY OF KIRKLAND APPROVING THE ISSUANCE OF A CONDITIONAL USE PERMIT AS APPLIED FOR IN DEPARTMENT OF COMMUNITY DEVELOPMENT FILE NO. CUP-78-66(P), BY G&B ESTATES, INC., TO CONSTRUCT A "SEA GALLEY" RESTAURANT ON THE SOUTH SIDE OF TOTEM LAKE WAY, BEING WITHIN A PLANNED AREA 8 ZONE, AND SETTING FORTH CONDITIONS TO WHICH SUCH CONDITIONAL USE PERMIT SHALL BE SUBJECT.

WHEREAS, the Department of Community Development has received an application for a Conditional Use Permit filed by G&B Estates, the owner of said property described in said application and located within a Planned Area 8 zone, and

WHEREAS, the application has been submitted to the Kirkland Planning Commission who held public hearing thereon at their regular meetings of October 26, 1978, and November 16, 1978, and

WHEREAS, pursuant to City of Kirkland Ordinance No. 2319 concerning environmental policy of the State Environmental Policy Act, an environmental checklist has been submitted to the City of Kirkland, reviewed by the responsible official of the City of Kirkland and a negative declaration reached, and

WHEREAS, said environmental checklist and declaration have been available and accompanied the application through the entire review process, and

WHEREAS, the Kirkland Planning Commission after their public hearings and consideration of the recommendations of the Department of Community Development and having available to them the environmental checklist and negative declaration did adopt certain Findings, Conclusions and Recommendations and did recommend approval of the Conditional Use Permit subject to the specific conditions set forth in said recommendations.

NOW, THEREFORE, BE IT RESOLVED by the City Council of the City of Kirkland as follows:

Section 1. The Findings, Conclusions and Recommendations of the Kirkland Planning Commission as signed by the Chairperson thereof and filed in the Department of Community Development File No. CUP-78-66(P) are adopted by the Kirkland City Council as though fully set forth herein.

Section 2. The Conditional Use Permit shall be issued to the applicant subject to the conditions set forth in the Recommendations hereinabove adopted by the City Council.

Section 3. A certified copy of this Resolution, together with the Findings, Conclusions and Recommendations therein adopted shall be attached to and become a part of the Conditional Use Permit or evidence thereof delivered to the permittee.

Section 4. Nothing in this section shall be construed as excusing the applicant from compliance with any federal, state or local statutes, ordinances or regulations applicable to this project, other than expressly set forth herein,

Section 5. Failure on the part of the holder of the Conditional Use Permit to initially meet or maintain strict compliance with the standards and conditions to which the Conditional Use Permit is subject shall be grounds for revocation in accordance with Section 23.56.110 of Ordinance No. 2183, the Kirkland Zoning Ordinance.

Section 6. Certified or conformed copies of this Resolution shall be delivered to the following:

- (a) Applicant
- (b) Department of Community Development of the City of Kirkland
- (c) Building Department of the City of Kirkland
- (d) Fire Department of the City of Kirkland
- (e) Police Department of the City of Kirkland
- (f) Parks Department of the City of Kirkland
- (g) Public Service Department of the City of Kirkland
- (h) The Office of the Director of Administration and Finance (ex officio City Clerk) for the City of Kirkland

ADOPTED in regular meeting of the City Council on the 4th day of December , 1978 .

SIGNED IN AUTHENTICATION THEREOF on the 4th day of December 1978.

  
\_\_\_\_\_  
Robert H. Klein  
Mayor

ATTEST:

  
\_\_\_\_\_  
Tom J. Anderson  
Director of Administration and Finance  
(ex officio City Clerk)



## DEPARTMENT OF COMMUNITY DEVELOPMENT

# ADVISORY REPORT

## FINDINGS, CONCLUSIONS AND RECOMMENDATIONS

PREPARED BY \_\_\_\_\_ DATE \_\_\_\_\_

RECOMMENDED BY \_\_\_\_\_ DATE November 16, 1978

ADOPTED BY \_\_\_\_\_ DATE \_\_\_\_\_

STAFF \_\_\_\_\_

BOARD OF ADJUSTMENT \_\_\_\_\_

HOUGHTON COMMUNITY COUNCIL \_\_\_\_\_

PLANNING COMMISSION David Russell  
\_\_\_\_\_  
David Russell, Chairperson

CITY COUNCIL AS INCORPORATED IN \_\_\_\_\_

RESOLUTION  ORDINANCE

NUMBER \_\_\_\_\_

DATE \_\_\_\_\_

FILE NUMBER CUP-78-66(P)

APPLICANT G&B ESTATES, INC.

PROPERTY LOCATION So. side of Totem Lake Way

SUBJECT CONDITIONAL USE PERMIT FOR "SEA GALLEY" RESTAURANT

HEARING/MEETING DATE December 4, 1978

BEFORE KIRKLAND CITY COUNCIL

EXHIBITS ATTACHED "A" Application "B" Vicinity/Site Maps "C" Recommendations

of Totem Lake So. Informal Subdivision "D" Totem Lake So. Informal Subdivision

"E" Information from Earth Consultants "F" Environmental Information "G" Sign Plan

## I. SUMMARY

### A. DESCRIPTION OF THE PROPOSED ACTION:

This is an application for a Conditional Use Permit submitted by Bill Vieser of G & B Estates. The applicants propose the construction of a "Sea Galley" restaurant of approximately 6600 square feet. This restaurant would be located on the south side of Totem Lake Way (see Vicinity Map - Exhibit "B").

The proposed restaurant would be situated in the northeast corner of the lot. Sixty-six parking stalls are included in the proposed site plan, as well as landscaping.

### B. RECOMMENDATIONS

This application is consistent with the applicable policies and recommendations of the City of Kirkland. Subject to the Statements of Fact and Conclusions and as identified in Exhibits "A" through "G", we hereby recommend approval with the following conditions:

1. No fill will be permitted below the 120 foot contour line.
2. Together with application for Building Permit, the applicant shall indicate the manner in which the structural recommendations of the soils engineers have been incorporated.
3. Prior to issuance of Building Permits for the subject property, the applicant shall:
  - a. Submit for review and approval to the Department of Community Development and Parks Department a detailed landscaping plan. Said plan shall indicate a 3 to 4 foot high earthen berm to be constructed along the northern perimeter of the project. Said berm shall be contoured so as to provide site screening along Totem Lake Way and shall be planted with ivy or similar erosion-reducing ground cover. The use of "beauty bark" is explicitly prohibited except where reasonably used as mulch. In addition, street trees and shrubs will be indicated along the landscaped berm, the former to occur at a maximum of 30 feet on center and both plant materials to be consistent with plantings on adjacent properties.

I. B. 3. b. Submit for review and approval to the Public Service Department the following items:

- (i) A storm retention system designed for 10-year storm, including methods or techniques for handling storm water runoff during construction as well as after. The retention system shall include oil/grit separators and these shall be indicated on the plans submitted for review.
  - (ii) A detailed utility improvement plan indicating the location, specifications and nature of the systems including water, sewer, power and communications. Applicant shall contact the N.E. Lake Washington Sewer District and then meet with the Kirkland Public Service Department. It shall be the purpose of said meeting to review the utility plan for conformance with Sections 4 and 5 of Resolution 2240 (minimizing hazard of flood damage or infiltration of flood waters into the sanitary sewer system).
- c. Contact the Department of Fire Services for the purpose of reviewing the detailed improvements so that fire flow, hydrant, water line location, and other relevant requirements are adequately addressed.
- d. Prior to the issuance of grading or building permits the applicant shall submit a temporary erosion-sedimentation control plan (TESCP) for review and approval to the King County Conservation District. Said plan shall meet the best management practices as recommended and approved by the District, including the prevention of the entrance of sediment laden water into the natural drainage system. These practices and facilities shall be in operation prior to clearing and building construction, and satisfactorily maintained until construction and landscaping are completed and the potential for on-site erosion has passed. The Conservation District shall transmit a letter to the Kirkland Department of Community Development stating that an adequate TESCP has been submitted by the applicants before any permits issue.
4. Prior to the issuance of Certificates of Occupancy, the following shall be accomplished:
- a. A five foot wide concrete sidewalk section shall be installed where the subject property abuts public right-of-way.
  - b. The earthen berm and plant materials described in the approved landscape plan shall be installed and ready for final inspection by the Department of Community Development.
  - c. A Conditional Use Permit shall have been processed and approved for any signs that are not face mounted on buildings.

## II. MAJOR STATEMENTS OF FACT AND CONCLUSIONS

### A. HISTORICAL BACKGROUND

#### 1. Statements of Fact

- a. The subject property is identified as Lot C of the short plat of Totem Lake. This short plat was approved by the City of Kirkland on April 14, 1977. (See Exhibit "D" - Short Plat of Totem Lake). This application was subject to specific recommendations found in Resolution No. R-2402, and these recommendations are included for reference in Exhibit "C".

### B. GOVERNMENTAL COORDINATION

#### 1. Statements of Fact

- a. Fire Department. Adequacy of Emergency Access: The "emergency access" as shown on the submitted drawing is adequate for emergency vehicles. Fire Hydrants: An additional fire hydrant may be required. This cannot be determined until a site plan is submitted showing the accesses in relation to the existing fire hydrants on Totem Lake Way. The aforementioned site plan shall be submitted and approved by the Fire Department before a Building Permit is issued. Adequacy of Fire Flow: When a more detailed set of plans is submitted to and approved by the Fire Department a minimum fire flow requirement can be calculated. Other: An alarm system may be required. Until more detailed drawings of the building are submitted this cannot be determined. The aforementioned drawings shall be submitted and approved by the Fire Department before a Building Permit will be issued.
- b. Building Department. Relevant Building Code Requirements: The building will be located in Fire Zone 2 and should be designed as such.
- c. Police Department. Emergency access is adequate. No other public safety concerns with this Conditional Use Permit.
- d. Parks Department. Pedestrian Improvements: Sidewalks on Totem Lake Way. Landscaping: To be approved by Parks Department General plan to match the street planting of adjacent properties. Street trees 30' on center.

II. B. 1. e. Public Service Department. Sewer. Available from N.E. Lake Washington Sewer District. Water. Available from Water District 79. Right-of-way improvements. 5 foot concrete sidewalks along Totem Lake Way. Storm Sewer. Storm water retention will be required.

2. Conclusions

- a. The applicant must satisfy all requirements of the Kirkland Fire Department, with the location of a fire hydrant to be determined at the time of Building Permit application, if such hydrant is necessary.
- b. Sidewalks should be required along Totem Lake Way, and landscaping along that street should meet the approval of the Kirkland Parks Department.
- c. The storm water retention plans must be approved by the Department of Public Service.

C. EXISTING PHYSICAL CHARACTERISTICS:

1. Statements of Fact

- a. Topography. The contour lines of the subject property are shown on the site plan. (See Exhibit "C"). Most of the property has a gentle slope towards the lake, but there is steeper topography at the northeast corner of the property with a maximum slope of 19%.
- b. Vegetation. The northern portion of the site which has been filled in the past is covered with such vegetation as Scotch Broom, Fireweed, Alder, Cottonwood, and grasses. The marshland on the southern portion of the property is covered with species such as Willows, young Red Alder, Cottonwood, Cattails, Reeds, and grasses.
- c. Soils. The underlying soil in the Totem Lake area is Vashon-Age Glacial Outwash Till. Over much of the subject property, manmade fill of varying density has been placed over the original soil. On the southern portion of the property, soft organic materials including silt and peat overlie the glacial till.

Earth Consultants, Inc. has conducted a soil investigation for the subject property. Their borings found that the building site is underlain by up to nineteen feet of loose to medium dense silty sand fill which was placed directly upon two to four feet of soft peat. (See Exhibit "E").

11/16/78  
10/17/78 bk

II. C. 1. d. Hydrology. Runoff from the subject property drains into Totem Lake. This lake is a shallow remnant of a larger lake which was originally a melt water channel. The lake has been in the process of eutrophication for the past eight to nine thousand years.

2. Conclusions.

- a. Topography/soils/geology. Special caution must be taken with construction on variable fill and soft organic materials. The recommendations of the soils engineers must be followed by the developer.
- b. Hydrology. To prevent further eutrophication of the lake, special care must be taken to insure high water quality of runoff entering the lake. The applicant's plans for storm water runoff will require approval from the Department of Public Service.
- c. Vegetation. Most of the existing vegetation will be removed by the development as proposed. Other species will replace a portion of the removed vegetation. The hydrology of the area and the characteristics of the soil should be taken into account in selecting landscaping materials along the southern portion of the property.

D. PUBLIC UTILITIES

1. Statements of Fact

- a. Streets. The subject property fronts on Totem Lake Way. The portion of this street on which the subject property fronts has been improved with asphalt, curb, and gutter.
- b. Pedestrian Ways. There are no existing sidewalks on the frontage of the subject property.
- c. Domestic Water. Domestic water is available through Water District No. 79.
- d. Sanitary Sewer. The property is in the Northeast Lake Washington Sewer District, and could be served by an existing 10" sanitary sewer line along 120th Ave. N.E.

II. D. 1. e. Storm Sewer. Storm sewer would be discharged into Totem Lake and the associated wetlands.

E. NEIGHBORHOOD CHARACTERISTICS:

1. Statements of Fact

- a. Zoning. The subject property is zoned Planned Area 8. Professional offices, restaurants, multi-family dwelling units, or limited commercial uses are allowed in Planned Area 8. Restaurants in this Planned Area are subject to Chapter 23.14 of the Zoning Ordinance, Professional Office Zone.
- b. Land Use. The subject property is presently undeveloped excluding that portion of Totem Lake Way which was previously constructed. The property surrounding this site is varied and includes the Totem Lake Shopping Complex, and presently vacant land. The owners of the property to the east and to the west of the subject parcel have applied for development permits. To the west, the request for Conditional Use Permit includes a restaurant, a delicatessen, and a liquor store. The City has received an application for 119 residential units directly to the east of the subject property.

2. Conclusions

This proposal is consistent with the allowable uses for Planned Area 8 and would not be out of character with existing development.

F. LOCAL ZONING AND/OR LAND USE POLICIES AND PLANS

1. Statements of Fact

- a. Kirkland Zoning Ordinance. This proposed restaurant would be subject to the requirements of Section 23.14 of the Zoning Ordinance, and the applicable regulations found in Section 23.32, Signs, and Section 23.34, Parking and Loading.
- b. Land Use Policies Plan. The applicable sections of the Land Use Policies Plan are noted as follows:

Totem Lake is also an important element in the drainage system. This small lake provides storage for urban runoff; acts to some extent as a trap for sediment carried by surface runoff; and provides open space amenities in an area undergoing intense development. Totem Lake should be maintained in a natural condition and should not be diminished in size by filling or other land modifications (see Natural Elements Policy 2 and Policy 4). (P. 392 and 393)

Lands surrounding the five-acre Totem Lake may be subject to uneven settlement (see Figure 41). In this area, developments must include methods to handle drainage; prevent methane entrapment; and prevent the settlement of structures and utility systems (see Natural Elements Policy 1.b.). In all areas subject to uneven settlement, a soils analysis is required prior to development in order to identify and mitigate possible problems. Further discussion of potential development around the Lake may be found in the Planned Areas section. (P. 393 and 394)

Portions of the Totem Lake area have been designated as flood hazard zones as illustrated in Figure 41. These designations have been made by the Federal Insurance Administration of Department of Housing and Urban Development. Federal law requires that flood insurance be obtained before any federally insured lending institution may approve a loan for development within an identified flood hazard zone. (P. 394)

Totem Lake and the surrounding wetlands have been identified as a natural constraint area. These lands have been noted as being subject to possible uneven settlement and have been designated by the Federal government as a flood hazard zone. Additionally, the lake and wetlands area are to be maintained as functioning elements of the natural drainage system (see Natural Elements Policy 4 and Public services/Facilities: Drainage Policy 1). To protect the lake, to provide visual open space, because most of the land is in a single ownership and considering the natural constraints, the area has been designated a Planned Area. Possible uses would include limited commercial and small office uses. Also permitted would be medium density residential use at 10 to 14 dwelling units per acre. All developments will be subject to the following conditions:

- (1) Developments are to be part of a plan encompassing all of the Planned Area.
- (2) The assured maintenance of the lake and wetlands as a natural water retention and cleansing system will be required (see Natural Elements Policy 4 and Public Services/Facilities: Drainage Policy 1).
- (3) The lake is to remain as a visual focal point for the area.
- (4) No construction over the lake will be permitted.
- (5) No fill for structures or parking will be permitted within a reasonable distance from the lake.
- (6) The water surface area of the lake is not to be reduced.
- (7) Lands which have been encumbered with a dedication of open space or development rights to the City may not be included in residential density computations.

(p. 396 & 397)

Totem Lake has been designated as a flood hazard area by the Federal Insurance Administration (under HUD) and therefore is subject to the following sections of Resolution 2240.

"Section 4: The Building Official acting in cooperation with the Director of Public Services shall review subdivision proposals and other proposed new developments to assure that

- (i) All such proposals are consistent with the need to minimize flood damage;
- (ii) All public utilities and facilities such as sewer, gas, electrical and water systems are located, elevated and constructed to minimize or eliminate flood damage; and
- (iii) Adequate drainage is provided so as to reduce exposure to flood hazards.

Section 5: The Building Official acting in cooperation with the Director of Public Services shall require new or replacement water supply systems and/or sanitary sewage systems to be designed to minimize or eliminate infiltration of flood waters into the systems and discharges from the systems into flood waters, and require on-site waste disposal systems to be located so as to avoid impairment of them or contamination from them during flooding."

## II. F. 2. Conclusions.

- a. Totem Lake will be retained in its present condition below the 120 foot contour level. This will preserve the open space amenity and the hydrological value of the lake.
- b. Construction designs must take into account the problems associated with uncompacted fill. The plans will require approval from the Building Department and the Department of Public Service. The review of these plans should observe the policies embodied in the Comprehensive Plan.
- c. This development proposal generally meets the seven policy guidelines found on pages 396-397 which apply to the subject property.
- d. The utilities improvements must conform with Sections 4 and 5 of Resolution No. R-2240 in order to minimize any flood damage or infiltration of flood waters into the sanitary sewer system.

## III. APPENDICES

Exhibits "A" through "G" are attached.